

情報開示資料9 令和7年度雨天時塩素注入率データ

前橋水質浄化センター 処理状況

令和7年

日付	曜日	平均気温 (℃)	降水量 (mm)	1,2系塩素混和地			3系塩素混和地		
				次亜塩素注入量 (L)	放流水流量 (m3)	次亜塩素注入率 (mg/L)	次亜塩素注入量 (L)	放流水流量 (m3)	次亜塩素注入率 (mg/L)
4/1	火	5.9	19.5	538.0	45,660	1.63	147.1	14,975.0	1.36
4/2	水	10.1	14.5	608.0	53,970	1.55	263.6	21,189.0	1.72
4/3	木	8.5	4.0	365.0	36,960	1.36	179.8	15,200.0	1.63
4/10	木	13.3	3.0	175.0	26,070	0.93	138.3	13,751.0	1.39
4/11	金	15.1	5.0	289.0	30,780	1.30	157.8	14,491.0	1.50
4/13	日	11.1	17.5	473.0	41,870	1.56	217.6	17,563.0	1.71
4/14	月	15.5	11.5	524.0	52,470	1.38	236.8	19,503.0	1.68
4/20	日	19.3	2.0	207.0	26,110	1.09	139.5	13,775.0	1.40
4/23	水	17.1	1.5	234.0	27,020	1.20	157.6	12,687.0	1.71
4/28	月	16.8	5.5	320.0	31,330	1.41	195.7	15,172.0	1.78
5/2	金	15.7	52.5	562.0	49,800	1.56	317.3	22,188.0	1.97
5/6	火	14.0	16.5	449.0	45,160	1.37	276.6	20,745.0	1.84
5/7	水	15.7	7.0	399.0	45,800	1.20	218.9	18,452.0	1.64
5/9	金	17.5	2.5	266.0	30,930	1.19	159.5	15,116.0	1.46
5/10	土	17.1	3.0	326.0	37,500	1.20	171.9	15,854.0	1.50
5/12	月	16.0	3.0	298.0	34,270	1.20	168.4	15,545.0	1.49
5/17	土	19.3	12.5	374.0	40,920	1.26	143.2	18,107.0	1.09
5/22	木	23.7	16.5	507.0	44,550	1.57	123.7	16,376.0	1.04
5/24	土	16.9	13.5	399.0	36,790	1.50	127.9	15,315.0	1.15
5/25	日	18.1	9.5	516.0	48,620	1.46	109.6	19,405.0	0.78
5/30	金	16.1	6.5	356.0	41,600	1.18	115.2	14,618.0	1.09
5/31	土	15.9	20.0	648.0	46,280	1.93	143.8	19,143.0	1.04
6/3	火	17.9	21.0	791.0	58,340	1.87	129.6	25,898.0	0.69
6/10	火	20.3	5.0	313.0	37,310	1.16	136.2	16,435.0	1.14
6/11	水	21.0	33.5	753.0	55,790	1.86	153.0	26,022.0	0.81
6/14	土	20.3	12.0	525.0	47,260	1.53	137.2	20,742.0	0.91
6/15	日	25.5	12.5	624.0	55,590	1.55	135.6	23,259.0	0.80
6/23	月	25.0	7.5	413.0	42,920	1.33	126.4	18,023.0	0.97
6/24	火	24.7	2.0	358.0	42,920	1.15	122.3	17,032.0	0.99
6/25	水	25.6	23.0	627.0	49,770	1.74	136.6	22,079.0	0.85
6/26	木	26.8	3.5	491.0	51,510	1.32	115.0	19,121.0	0.83
7/1	火	28.1	40.5	501.0	46,810	1.48	122.8	20,296.0	0.83
7/10	木	27.7	3.0	420.0	43,360	1.34	125.8	18,793.0	0.92
7/11	金	23.2	1.5	353.0	42,830	1.14	130.7	17,989.0	1.00
7/14	月	27.4	4.5	344.0	41,120	1.15	126.9	18,071.0	0.97
7/15	火	26.3	16.0	678.0	54,650	1.71	135.3	25,743.0	0.73
7/16	水	27.2	2.5	349.0	43,520	1.11	130.2	19,012.0	0.95
7/17	木	27.5	7.5	534.0	50,700	1.45	139.5	21,978.0	0.88
8/7	木	26.9	17.0	489.0	45,770	1.47	143.3	20,271.0	0.98
8/9	土	27.7	2.5	346.0	40,610	1.18	107.5	17,742.0	0.84
8/10	日	24.9	13.0	502.0	52,850	1.31	137.5	18,901.0	1.00
8/11	月	27.2	3.0	369.0	46,630	1.09	144.6	17,318.0	1.15
8/12	火	26.1	4.5	362.0	46,370	1.08	158.7	17,245.0	1.27
8/15	金	29.4	7.5	421.0	42,680	1.36	140.3	17,875.0	1.08
8/16	土	28.7	1.5	391.0	45,380	1.19	146.6	16,573.0	1.22
8/17	日	30.3	16.5	480.0	48,960	1.35	130.4	18,218.0	0.99
8/24	日	31.2	10.0	353.0	39,070	1.25	147.6	17,766.0	1.15
9/2	火	30.3	2.0	399.0	39,440	1.40	124.8	17,880.0	0.96
9/4	木	26.7	2.5	372.0	38,570	1.33	111.7	16,411.0	0.94

前橋水質浄化センター 処理状況

令和7年

日付	曜日	平均気温 (℃)	降水量 (mm)	1,2系塩素混和地			3系塩素混和地		
				次亜塩素注入量 (L)	放流水流量 (m3)	次亜塩素注入率 (mg/L)	次亜塩素注入量 (L)	放流水流量 (m3)	次亜塩素注入率 (mg/L)
9/5	金	25.2	51.5	764.0	60,930	1.73	120.9	26,420.0	0.63
9/10	水	28.2	3.0	374.0	42,090	1.23	127.2	17,441.0	1.01
9/11	木	25.8	6.5	591.0	49,150	1.66	137.7	21,997.0	0.86
9/12	金	23.6	14.5	687.0	59,170	1.60	165.0	23,523.0	0.97
9/13	土	23.4	4.5	478.0	53,850	1.22	179.8	19,983.0	1.24
9/14	日	27.2	3.0	458.0	49,110	1.29	127.3	19,491.0	0.90
9/18	木	27.6	10.0	413.0	44,540	1.28	122.6	18,320.0	0.92
9/19	金	21.5	3.0	466.0	50,010	1.29	126.9	21,152.0	0.83
9/20	土	20.7	3.5	356.0	44,310	1.11	111.9	17,589.0	0.88
9/30	火	22.9	1.5	265.0	33,980	1.08	178.2	15,604.0	1.58
10/1	水	20.3	3.5	374.0	41,270	1.25	219.1	16,624.0	1.82
10/4	土	19.9	1.5	231.0	32,020	1.00	171.6	15,772.0	1.50
10/11	土	16.8	4.5	305.0	36,310	1.16	168.2	14,920.0	1.56
10/14	火	17.0	3.5	314.0	34,440	1.26	140.7	14,866.0	1.31
10/16	木	17.9	5.5	254.0	34,500	1.02	173.0	15,363.0	1.55
10/25	土	13.5	2.0	238.0	28,800	1.14	160.3	14,824.0	1.49
10/26	日	15.3	7.5	280.0	35,890	1.08	165.4	16,688.0	1.37
10/31	金	13.6	26.5	422.0	37,950	1.53	198.3	15,826.0	1.73
11/1	土	16.2	3.0	447.0	44,770	1.38	189.2	15,492.0	1.69
11/9	日	11.7	4.5	259.0	32,230	1.11	139.6	12,226.0	1.58
12/24	水	6.1	4.0	200.0	25,840	1.07	138.1	10,187.0	1.87
12/25	木	8.2	5.0	240.0	29,470	1.12	130.4	10,981.0	1.64
2/25	水	9.6	12.5	380.0	39,050	1.34	105.0	8,666.0	1.67
3/3	火	6.8	23.5	504.0	46,540	1.49	103.0	8,322.0	1.71
3/4	水	8.1	3.0	424.0	40,840	1.43	92.5	7,207.0	1.77
3/9	月	6.1	3.5	181.0	22,910	1.09	83.8	6,611.0	1.75
3/25	水	10.4	9.0	274.0	29,420	1.29	123.4	7,557.0	2.25
3/26	木	10.8	15.5	600.0	54,370	1.52	208.8	10,312.0	2.79
3/27	金	13.3	4.5	221.0	30,450	1.00	114.9	7,519.0	2.11
3/29	日	15.5	7.0	306.0	33,170	1.27	128.3	7,737.0	2.29

※降水量1mm以上の日を抽出

※天候・気温・降水量の出典：気象庁ホームページ（<http://www.jma.go.jp/jma/menu/menureport.html>）